



[CLICK HERE TO SIGN UP FOR BUILDINGS NEWS](#)

NYC Department of Buildings

Overview for Complaint #:1690793 = RESOLVED

Complaint at: 109 EAST 9 STREET **BIN:** 1008963 **Borough:** MANHATTAN **ZIP:** 10003
Re: FAILURE TO MAINTAIN

Category Code: 73 FAILURE TO MAINTAIN

Assigned To: MANHATTAN CONSTRUCTION ENFORCEMENT **Priority:** C

Received: 03/13/2025 12:34 **Block:** 555 **Lot:** 40 **Community Board:** 103
Owner: 109E9 LLC

Last Inspection: 03/19/2025 - - BY BADGE # 2725
Disposition: 03/20/2025 - A8 - ECB VIOLATION SERVED
ECB Violation #: 39142176K 39142177M
Comments: ATOI, MISSING FIRESTOPPING AND EXPOSED ELECTRICAL WIRING AT UNOCCUPIED ROOMS ON 4TH, 3RD AND 2ND FLS AND FIRESTOPPING INSTALLED AT 5TH FLOOR CEILINGS WITHOUT PERMIT - OATH SUMMONSES SERVED

Complaint Disposition History

#	Disposition Date	Disposition Code	Disposition	Inspection By	Date
---	------------------	------------------	-------------	---------------	------

If you have any questions please review these [Frequently Asked Questions](#), the [Glossary](#), or call the 311 Citizen Service Center by dialing 311 or (212) NEW YORK outside of New York City.