



[CLICK HERE TO SIGN UP FOR BUILDINGS NEWS](#)

NYC Department of Buildings

**DOB Violation Display for 081424CFEU10301PN**

Premises: 109 EAST 9 STREET MANHATTAN

BIN: [1008963](#) Block: 555 Lot: 40

Issue Date: 08/14/2024

Violation Category: V - DOB VIOLATION - ACTIVE

Violation Type: C - CONSTRUCTION

Violation Number: FEU10301PN

Device No.:

OATH/ECB No.:

Infraction Codes:

Description: EMERGENCY WORK ORDER.MAIN BLDG W/WOOD JOIST&CRCKD 3RD FL HEADER W/ INADEQUATE CONNECTION TO TRIMMER,WHICH WAS SUPPORTING INTERIOR WALL ADJ TO STAIRS.FLOORS SEVERELY SLOPING TOWARDS CENTER STAIRS@2ND THRU 5FLRS OWNR TO IMMEDIATELY RETAIN NYSPE&LICENSED GC TO SHORE BLDG,AS REQ'D,UNDER FULL TIME CONT,NYSPE SUPERVISION/DIRECTION

Disposition:

Code: Date:

Inspector:

Comments:

If you have any questions please review these [Frequently Asked Questions](#), the [Glossary](#), or call the 311 Citizen Service Center by dialing 311 or (212) NEW YORK outside of New York City.