



[CLICK HERE TO SIGN UP FOR BUILDINGS NEWS](#)

NYC Department of Buildings

DOB Violation Display for 081424CFEU10302PN

Premises: 109 EAST 9 STREET MANHATTAN

BIN: [1008963](#) Block: 555 Lot: 40

Issue Date: 08/14/2024

Violation Category: V - DOB VIOLATION - ACTIVE

Violation Type: C - CONSTRUCTION

Violation Number: FEU10302PN

Device No.:

OATH/ECB No.:

Infraction Codes:

Description: FAILURE TO MAINTAIN BLDG IN A SAFE CONDITION.MAIN BLDG&CRCKD 3RDFL
HEADER W/INADEQUATE CONNECTION TO TRIMMER WHICH WAS SUPPORTNG INTERIOR
WALL ADJ TO STAIRS.FLOORS SEVERELY SLOPNG TOWARDS.OWNR TO RTAIN NYSPE
TO EVAL THE ENT BLDG&FILE RPAIR DWGS W/DOB.PERM RPAIRS TO BEGIN UNDR
PRMT 10/14/24&CMPLTD&SGND OFF

Disposition:

Code: Date:

Inspector:

Comments:

If you have any questions please review these [Frequently Asked Questions](#), the [Glossary](#), or call the 311 Citizen Service Center by dialing 311 or (212) NEW YORK outside of New York City.